

FEDERAL EMERGENCY MANAGEMENT AGENCY
NATIONAL FLOOD INSURANCE PROGRAM

O.M.B. No. 3067-0077
Expires July 31, 2002

ELEVATION CERTIFICATE

Important: Read the instructions on pages 1 - 7.

SECTION A - PROPERTY OWNER INFORMATION			For Insurance Company Use:
BUILDING OWNER'S NAME EnProvence, LLC		Policy Number	
BUILDING STREET ADDRESS (Including Apt., Unit, Suite, and/or Bldg. No.) OR P.O. ROUTE AND BOX NO. 2141 Gulf of Mexico Drive (Building No. 1)		Company NAIC Number	
CITY Sarasota	STATE Florida	ZIP CODE 34228	
PROPERTY DESCRIPTION (Lot and Block Numbers, Tax Parcel Number, Legal Description, etc.) Tax Parcel Number 0008-04-0003			
BUILDING USE (e.g., Residential, Non-residential, Addition, Accessory, etc. Use Comments section if necessary.) Residential (Condominium above one parking level)			
LATITUDE/LONGITUDE (OPTIONAL) (##° - ##' - ##.###" or ##.#####")		HORIZONTAL DATUM: SOURCE: <input type="checkbox"/> GPS (Type): <input type="checkbox"/> NAD 1927 <input type="checkbox"/> NAD 1983 <input type="checkbox"/> USGS Quad Map <input type="checkbox"/> Other:	

SECTION B - FLOOD INSURANCE RATE MAP (FIRM) INFORMATION

B1. NFIP COMMUNITY NAME & COMMUNITY NUMBER Town of Longboat Key 125126		B2. COUNTY NAME Sarasota	B3. STATE Florida		
B4. MAP AND PANEL NUMBER 0010	B5. SUFFIX B	B6. FIRM INDEX DATE 5/18/92	B7. FIRM PANEL EFFECTIVE/REVISED DATE 8/15/83	B8. FLOOD ZONE(S) A13	B9. BASE FLOOD ELEVATION(S) (Zone AO, use depth of flooding) 12

B10 Indicate the source of the Base Flood Elevation (BFE) data or base flood depth entered in B9.
 FIS Profile FIRM Community Determined Other (Describe):

B11. Indicate the elevation datum used for the BFE in B9: NGVD 1929 NAVD 1988 Other (Describe):

B12. Is the building located in a Coastal Barrier Resources System (CBRS) area or Otherwise Protected Area (OPA)? Yes No
Designation Date:

SECTION C - BUILDING ELEVATION INFORMATION (SURVEY REQUIRED)


C1. Building elevations are based on: Construction Drawings* Building Under Construction* Finished Construction
*A new Elevation Certificate will be required when construction of the building is complete.

C2. Building Diagram Number 6 (See Attached Sketch) (Select the building diagram most similar to the building for which this certificate is being completed - see pages 6 and 7. If no diagram accurately represents the building, provide a sketch or photograph.)

C3. Elevations - Zones A1-A30, AE, AH, A (with BFE), VE, V1-V30, V (with BFE), AR, ARIA, AR/AE, AR/A1-A30, AR/AH, AR/AO
Complete Items C3a-i below according to the building diagram specified in Item C2. State the datum used. If the datum is different from the datum used for the BFE in Section B, convert the datum to that used for the BFE. Show field measurements and datum conversion calculation. Use the space provided or the Comments area of Section D or Section G, as appropriate, to document the datum conversion.
Datum _____ Conversion/Comments _____

Elevation reference mark used 17-84-A08-RM2 (See Notes) Does the elevation reference mark used appear on the FIRM? Yes No


a) Top of bottom floor (including basement or enclosure) _____ 8.8 ft.(m)
 b) Top of next higher floor _____ 20.5 ft.(m)
 c) Bottom of lowest horizontal structural member (V zones only) _____ N/A ft.(m)
 d) Attached garage (top of slab) _____ N/A ft.(m)
 e) Lowest elevation of machinery and/or equipment servicing the building _____ 12.0 ft.(m)
 f) Lowest adjacent grade (LAG) _____ 8.2 ft.(m)
 g) Highest adjacent grade (HAG) _____ 8.4 ft.(m)
 h) No. of permanent openings (flood vents) within 1 ft. above adjacent grade 0
 i) Total area of all permanent openings (flood vents) in C3h 0 sq. in. (sq. cm)



SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION

This certification is to be signed and sealed by a land surveyor, engineer, or architect authorized by law to certify elevation information.
I certify that the information in Sections A, B, and C on this certificate represents my best efforts to interpret the data available.
I understand that any false statement may be punishable by fine or imprisonment under 18 U.S. Code, Section 1001.

CERTIFIER'S NAME Robert R. Cunningham	LICENSE NUMBER 3924
TITLE Professional Surveyor and Mapper	COMPANY NAME WilsonMiller, Inc.
ADDRESS 6900 Professional Pkwy. E. # 100	CITY Sarasota
SIGNATURE <i>Robert R. Cunningham</i>	STATE FL
	ZIP CODE 34240
	TELEPHONE 941-907-6900



IMPORTANT: In these spaces, copy the corresponding information from Section A.			For Insurance Company Use:
BUILDING STREET ADDRESS (Including Apt., Unit, Suite, and/or Bldg. No.) OR P.O. ROUTE AND BOX NO. 2141 Gulf of Mexico Drive (Building No. 1)			Policy Number
CITY Town of Longboat Key	STATE Florida	ZIP CODE 34228	Company NAIC Number

SECTION D - SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION (CONTINUED)

Copy both sides of this Elevation Certificate for (1) community official, (2) insurance agent/company, and (3) building owner

COMMENTS

C2.: See attached sketch provided by Wilson Structural Consultants, Inc.

C3.h & C3.i: The lowest floor is surrounded by breakaway walls. See the attached letter from Wilson Structural Consultants, Inc., regarding breakaway walls. The lowest floor is parking, storage and ground floor lobby.

Elevations shown hereon are relative to the National Geodetic Vertical Datum (NGVD) 1929 based on CCCL Station 17-84-A08-RM2 with an

adjusted elevation of 10.74'.

Check here if attachments

SECTION E - BUILDING ELEVATION INFORMATION (SURVEY NOT REQUIRED) FOR ZONE AO and ZONE A (WITHOUT BFE)

For Zone AO and Zone A (without BFE), complete Items E1 through E3. *If the Elevation Certificate is intended for use as supporting information for a LOMA or LOMR-F, Section C must be completed.*

E1. Building Diagram Number _____ (Select the building diagram most similar to the building for which this certificate is being completed — see pages 6 and 7. If no diagram accurately represents the building, provide a sketch or photograph.)

E2. The top of the bottom floor (including basement or enclosure) of the building is ft.(m) in.(cm) above or below (check one) the highest adjacent grade.

E3. For Zone AO only If no flood depth number is available, is the top of the bottom floor elevated in accordance with the community's floodplain management ordinance? Yes No Unknown. The local official must certify this information in Section G.

SECTION F - PROPERTY OWNER (OR OWNER'S REPRESENTATIVE) CERTIFICATION

The property owner or owner's authorized representative who completes Sections A, B, and E for Zone A (without a FEMA-issued or community-issued BFE) or Zone AO must sign here.

PROPERTY OWNER'S OR OWNER'S AUTHORIZED REPRESENTATIVE'S NAME

ADDRESS CITY STATE ZIP CODE

SIGNATURE DATE TELEPHONE

COMMENTS:

Check here if attachments

SECTION G - COMMUNITY INFORMATION (OPTIONAL)

The local official who is authorized by law or ordinance to administer the community's floodplain management ordinance can complete Sections A, B, C (or E), and G of this Elevation Certificate. Complete the applicable item(s) and sign below.

G1. The information in Section C was taken from other documentation that has been signed and embossed by a licensed surveyor, engineer, or architect who is authorized by state or local law to certify elevation information. (Indicate the source and date of the elevation data in the Comments area below.)

G2. A community official completed Section E for a building located in Zone A (without a FEMA-issued or community-issued BFE) Zone AO.

G3. The following information (Items G4-G9) is provided for community floodplain management purposes.

G4. PERMIT NUMBER	G5. DATE PERMIT ISSUED	G6. DATE CERTIFICATE OF COMPLIANCE/OCCUPANCY ISSUED
-------------------	------------------------	---

G7. This permit has been issued for: New Construction Substantial Improvement

G8. Elevation of as-built lowest floor (including basement) of the building is: _____ . _____ ft.(m) Datum: _____

G9. BEE or (in Zone AO) depth of flooding at the building site is: _____ . _____ ft.(m) Datum: _____

LOCAL OFFICIAL'S NAME TITLE

COMMUNITY NAME TELEPHONE

SIGNATURE DATE

COMMENTS

Check here if attachments

WILSON STRUCTURAL CONSULTANTS, INC.

7184 BENEVA RD., SARASOTA, FL 34238

(941) 921-1072 * fax (941) 921-3871

October 30, 2001

Mr. Randy Fowler
Chief Code Enforcement Officer
Town of Longboat Key
Planning, Zoning & Building
561 Bay Isles Road
Longboat Key, FL 34228

RE: EN PROVENCE FLOW THRU VENTS

Dear Mr. Fowler:


We have reviewed the flow thru requirements for Buildings 1 and 3 at En Provence. It is our professional opinion that flow thru vents are not required in these two buildings because they have been designed with breakaway wall per Florida Department of Environmental Protection requirements. Breakaway construction, by its very nature will provide equalization of hydrostatic and hydrodynamic flood forces on all walls at the lower levels.

The construction complies with V-Zone requirements for breakaway walls where hydrostatic relief vents are not required by FEMA.


Please contact us if you have any more questions regarding this issue.

Sincerely

WILSON STRUCTURAL CONSULTANTS, INC.



Richard D. Wilson, P.E.



RECEIVED
OCT 31 2001
BUILDING DEPARTMENT
TOWN OF LONGBOAT KEY
10/30/01

BUILDING DIAGRAM

BUILDINGS ELEVATED ON PIERS, POSTS, COLUMNS OR PARALLEL SHEAR WALLS WITH FULL OR PARTIAL ENCLOSURE BELOW THE ELEVATED FLOOR.

