



NOTE: THIS DRAWING IS TO BE USED FOR OFF-SITE FORCE MAIN AND WATER MAIN ONLY.

NOTE: DATE IN BRACKETS CONFORM DRAWINGS TO CONSTRUCTION RECORDS BY TRID SEPTEMBER 1992

- NOTES:
- CONTRACTOR SHALL SLIP LINE APPROXIMATELY 607 L.F. OF 15" FIBERGLASS PIPE FROM THE EXISTING LIFT STATION TO THE MANHOLE AT STA. 63+65.
 - THE CONTRACTOR SHALL CONSTRUCT A JUNCTION BOX WITH A TEMPORARY PENETRATION OF THE 15" SANITARY SEWER ENCLOSE SEWER IN A SPLIT CASING OF DUCTILE IRON OR STEEL REMOVE SANITARY SEWER AND GROUT WALLS UPON COMPLETION OF 6" PVC FORCE MAIN.
 - CONTRACTOR SHALL CONSTRUCT ± 60 LINEAL FEET OF 10" PVC ANWA C-900 DR 18 PIPE DEFLECTED UNDER PROPOSED 24" X 38" RCP. USE TRANSITION COUPLING FOR CONNECTION TO EXISTING 10" A.G.
 - THE CONTRACTOR SHALL USE THE EXISTING MANHOLE @ STA. ± 67+30 AS THE INSERTION POINT FOR SLIP LING BOTH MANHOLE RUNS. CONTRACTOR SHALL REPLACE MANHOLE WITH NEW MANHOLE UPON COMPLETION OF SLIP LING OPERATION.

- LEGEND:
- BACK OF CURB
 - C.L. CENTERLINE
 - EXISTING SPOT ELEVATION
 - VALVE
 - FIRE HYDRANT
 - POWER POLE
 - LIGHT POLE
 - CABLE TV RISER
 - ELECTRICAL RISER
 - GAS RISER
 - WATER LINE
 - SANITARY SEWER LINE
 - FIRE LINE
 - GAS LINE
 - CABLE TV
 - CLEAROUT
 - DIRECTION OF FLOW
 - TOP OF PIPE

DESIGNED BY	J.M.B.	DATE:	JULY, 1990
CHECKED BY	E.P.	PROJECT NO.	2591
DRAWN BY	E.P.	DESIGNED BY	J.M.B.
SCALE:	HOL. 1" = 20'	CHECKED BY	J.M.B.
BY	M.Y.M.	DRAWN BY	E.P.
DATE	12/15/90	DATE	12/15/90
REVISION	12/15/90	DATE	12/15/90
1	12/15/90	DATE	12/15/90
2	12/15/90	DATE	12/15/90
3	12/15/90	DATE	12/15/90
4	12/15/90	DATE	12/15/90

FOR: YALE PROPERTIES

CONSULTING ENGINEERS & SURVEYORS

SMALLY, WELLFORD & NALVEN, INC.

133 SOUTH MCINTOSH RD. SARASOTA, FLA. 33558

PROPOSED OFF-SITE FORCE MAIN & WATER MAIN

13

INDEX NO. G-25-25-1-018