



- NOTES:
 (SLAB ON GRADE)
 1) 4" CONC. SLAB W/ 6x6 W1.4xW1.4 W.H.M. ON VAPOR BARRIER & CLEAN COMPACTED FILL.
 2) CONTROL JOINTS: SAWCUT CONTROL JNTS. AT APPROX. 25'-0" SQ'S CUT 1/5 SLAB THICKNESS WITHIN 24 HOURS AFTER POUR DISCONTINUE MESH OR CUT EVERY OTHER WIRE @ JOINT.
 3) CONCRETE STRENGTH = 3000 P.S.I.
 4) SLAB EDGES NOT OCCURRING @ WALLS TO HAVE A 8" DEEP (MIN) x 8" WIDE HAUNCH W/ #5 CONT POUR W/ SLAB SEE SECTIONS FOR DETAILS
 5) REINFORCING STEEL:
 GRADE = A015.00
 LAP = 40 x BAR DIA.
 COVER = 3" CONC. COVER @ HAUNCHES
 6) HATCH WALLS INDICATED WALLS TO EXTEND TO UNDERSIDE OF 1ST FLR. SLAB