

**LEGEND**

**CHANGE IN PRIORITY BAR PLACEMENT**

① FIRST PRIORITY  
 ② SECOND PRIORITY  
 ③ THIRD PRIORITY

**SLAB STEPS AND SLOPES**  
 (SEE ARCHITECTURAL DRAWINGS FOR EXACT LOCATIONS)

④ 3/4" DAP OUT  
 ⑤ 3/4" STEP AT WALL LINE AND SLOPE SLAB TO EDGE

**SLAB THICKNESS IN INCHES**  
 (SEE ARCHITECTURAL DRAWINGS FOR SLOPE DETAILS)

5-1/2	6-3/4	7-1/2
6	7	7-3/4
6-1/2	7-1/4	8

SLAB THICKNESSES SHOWN ARE MINIMUM DIMENSIONS.

**SLAB NOTES**  
 SLAB THICKNESS = 8" (EXCEPT WHERE NOTED ON TOP STEEL SHT.)  
 CONCRETE STRENGTH = 4000 PS-I.  
 REINFORCING STEEL  
 GRADE = A615-60  
 PLACEMENT NOTES & DETAILS = SHT. # S-14  
 (\*) BARS ARE ADD BARS & ARE IN ADDITION TO GRID REINF. SHOWN ON PLAN.

**REFERENCE NOTES**  
 COLUMN SCHEDULE = SHT. # S-15  
 SHEARWALL SCHEDULE = SHT. # S-16  
 BEAM SCHEDULE = SHT. # S-17

