



- NOTES:  
 (SLAB ON GRADE)
- 1) 4" CONC. SLAB W/ 6x6 W.I. 4xW.I. 4 W.W.M. ON VAPOR BARRIER & CLEAN COMPACTED FILL
  - 2) CONTROL JOINTS: SAHCUT CONTROL JNTS. AT APPROX. 25'-0" SQ'S CUT 1/5 SLAB THICKNESS WITHIN 24 HOURS AFTER POUR. DISCONTINUE MESH OR CUT EVERY OTHER WIRE @ JOINT
  - 3) CONCRETE STRENGTH = 3000 P.S.I.
  - 4) SLAB EDGES NOT @ WALLS TO HAVE A 8" DEEP (MIN) x 8" WIDE HAUNCH W/ 1#5 CONT. POURED W/ SLAB SEE SECTIONS FOR DETAILS.
  - 5) REINFORCING STEEL:  
 GRADE = A015-00  
 LAP = 40 x BAR DIA.  
 COVER = 3" CONC. COVER @ HAUNCHES
  - 6) HATCH WALLS INDICATES WALL TO EXTEND TO UNDERSIDE OF 1ST FLOOR SLAB