



SLAB NOTES
 SLAB THICKNESS = 8" (EXCEPT WHERE NOTED ON TOP STEEL SHEET).
 CONCRETE STRENGTH = 4000 PSI.
 REINFORCING STEEL GRADE = A615-60
 PLACEMENT NOTES & DETAILS = SHEET S-14. (+) BARS ARE ADD BARS AND ARE IN ADDITION TO GRID REINFORCING SHOWN ON PLAN.

REFERENCE NOTES
 COLUMN SCHEDULE = SHEET #S-15
 SHEARWALL SCHEDULE = SHEET #S-16
 BEAM SCHEDULE = SHEET #S-17

BOTTOM STEEL TO BE A CONT. GRID OF #4 @ 13" O.C. EA. WAY (+) ADD BARS INDICATED ARE IN ADDITION TO GRID STEEL EXCEPT AS NOTED IN 19'-2" BAY

SLOPING CONG. CAP BEAM ABOVE BEAM (B) 8x12" W/ 4 #5 CONT. & #3 STIR. @ 18" O.C. & #4 @ 4" O.C. VERT. OUT OF BM B INTO CAP BM.

WOOD TRUSSES @ 24" O.C. IN GREAT FILLED CELLS

SECTION A-A
 1/2" = 1'-0"

SUNSET BEACH
 OF LONG BEACH, CALIF.
 BENNETT & BISHOP, INC. CONSULTING ENGINEERS & SURVEYORS

BLDG. - #3
SECOND FLOOR
BOTTOM STEEL PLAN
 1/8" = 1'-0"

ISSUED	12-10-82
REVISED	1-4-83
	11-11-83

SHEET
S. 6
 OF 24