



NOTE: Typical stirrup spacing shall be at 7" on center from edge of support to the 1/4 point and at 16" on center between 1/4 points. Provide #4 bar as required to support stirrups.

DETAIL # 2
4" CONDUIT (MIN. WALL = 110")
2" CONDUIT (MIN. WALL = 0 070")

DETAIL # 3

BENNETT & BISHOP
FLORIDA
CONSULTING ENGINEERS & SURVEYORS

ARVIDA CORPORATION
BAY ISLES - HARBOUR MOORINGS
CONCRETE BEAM DETAILS