



- NOTE:
1. STATIONS FOR WYES ARE SEWER STATIONS.
 2. STATIONS FOR WATER MAIN ANGLE POINTS ARE DRIVE STATIONS.
 3. SANITARY MANHOLES ARE SHOWN BOTH WAYS (STATIONS).
 4. PROVIDE CLEAN-OUTS IN SANITARY SERVICES AS REQUIRED BY PLUMBING CODE.
 5. PRIOR TO PROCEEDING WITH OTHER CONSTRUCTION, THE CONTRACTOR SHALL LOCATE THE 8" EXISTING SANITARY SEWER AT THE LOCATION OF PROPOSED M.H. SF-4.1 AND VERIFY THE EXISTING INVERT ELEVATION. NOTIFY THE ENGINEER OF ANY DISCREPANCY. SAME FOR M.H. 4F-26 D.
 6. ALL V.C. SANITARY SEWER PIPE TO BE "EXTRA STRENGTH".
 7. INFILTRATION NOT TO EXCEED 250 GALLONS PER INCH DIAMETER, PER MILE, PER 24 HOURS.
 8. EASEMENTS FOR SEWER AND WATER WILL BE PROVIDED 10' EACH SIDE OF EACH UTILITY AND A 10' WIDE EASEMENT FROM THE PRIVATE DRIVE TO INCLUDE THE WATER METERS.

NEAL & BOWYER, INC.
HARBOUR OAKS

SANITARY COLLECTION SYSTEM - NORTH
WATER DISTRIBUTION SYSTEM

SARASOTA CO., FLORIDA

BENNETT & BISHOP
CONSULTING ENGINEERS & SURVEYORS
FLORIDA

DATE	SCALE	VISION	DRAWN	CHECK	APPROVED	DATE	DESCRIPTION
3-9-83	1"=40'		JWH/WK				PHASE I
4-26-83							REVISE SAN SEWER
5-24-83							STRUCTURE LOCATIONS CALCULATED
6-15-83							NOTE (1) INSTALL M.H. SF-4.1
							PROPOSED WELL LOCATION ADDED

LONGBOAT KEY

DWG NO
310-019