



LEGEND
 — 3" V.C. PIPE 4 M.H., UNLESS NOTED
 ⊕ APPROX. GRADE
 -1.0 PIPE INVERT

LIFT STATION DATA			
STATION	UNITS	FLOW (GPM)	
		AVERAGE	DESIGN
L.S. 4F"	423	70	300
5F"	450 + CON.	84	330
6F"	126 + CLUB	46	184
7F"	1760	275	688
8F"	333	52	205

Scale: 1" = 400'

DATE	DESCRIPTION	BY
2-5-81	ADDED APPROXIMATE GRADES AND	M.A.
4-22-81	ADDED HARBOURSIDE CLUBHOUSE AREA	M.A.
2-26-82	ADDED SERVICE MAINTENANCE AREA	M.A.
2-9-82	RELOCATED 6" V.C. PIPE (See Note 1) To 1/2" P.V.	M.A.
1-18-82	ADDED 12" V.C. PIPE (See Note 2) To 1/2" P.V.	M.A.
3-2-82	ADDED 12" V.C. PIPE (See Note 3) To 1/2" P.V.	M.A.
3-23-82	ADDED 12" V.C. PIPE (See Note 4) To 1/2" P.V.	M.A.
7-23-79	REV. 6" V.C. PIPE TO 8" V.C. PIPE TO 12" V.C. PIPE	M.A.
11-17-79	REV. 6" V.C. PIPE TO 8" V.C. PIPE TO 12" V.C. PIPE	M.A.
11-17-79	REV. 12" V.C. PIPE TO 18" V.C. PIPE TO 24" V.C. PIPE	M.A.
12-11-79	ADDED 2" V.C. PIPE IN CORNER AREA	M.A.

BENNETT & BISHOP
 CONSULTING ENGINEERS & SURVEYORS
 SARASOTA FLORIDA
William Bishop #5889
 APPROVED BY

DATE	SCALE	DESIGN	DRAWN	CHECK	APPROVED
8/15/75	1"=400'	G.L.B.	G.L.B.		

ARVIDA CORPORATION
BAY ISLES
SANITARY SEWERAGE MASTER

LONGBOAT KEY PHONE 380-2172
 DWG. NO. 191-074