

TOWN OF LONGBOAT KEY FLORIDA

INCORPORATED NOVEMBER 14, 1955



501 Bay Isles Road
Longboat Key, Florida 33548
(813) 383-3721

October 27, 1989

Jim Dickens
Arvida Contractors
595 Bay Isles Road
Longboat Key, Fl. 34228

Re: SABAL COVE

Dear Jim:

The utility work on the above referenced project is approved in accordance with the plans received 10/24/89 and the specifications received 9/25/89, with the following conditions:

1. The PVC fittings for sewer must be compatible with the pipe and approved by the Town.
2. All fire systems must be installed after the domestic meter with a double check valve assembly approved by the Town.
3. A temporary, above ground, hose connection with 3/4" male thread and vacuum breaker shall be installed and maintained on the consumer side of the meter until the permanent connection is made.
4. Manhole bases shall be monolithically cast with bottom section 4" outside of walls.
5. No SDR-35 pipe will be allowed on Longboat Key.
6. No corrugated plastic drainage pipe will be allowed on Longboat Key.


Jim Dickens
October 27, 1989

Page Two

7. This approval is issued on condition that construction comply with all Town standards whether shown or noted on the plans.

If there are any questions, please let me know.

Very truly yours,



Leonard A. Smally
Director of Public Works

/cmm

cc: William Bishop
Roy Wamsley
Town Inspector