



State of Florida
Department of Environmental Regulation

Request for Letter of Release to Place Water Supply System into Service

I. General Information

Name of Project: L'Ambiance

Permit No. WD 1098-90-002

Date of Issuance 10/26/90

System completed to the full extent of the approved plans

Partially completed to the extent noted herein

Potable water lines to serve the south building, and pool area; included is the connection to the Town of Longboat Key water main.

II. Engineer's Certification

This is to certify that the project has been substantially completed in accordance with approved plans and specifications, or that the deviations noted on the attached record drawings will not prevent the system from functioning in compliance with requirements of Chapter 17-555, Florida Administrative Code (F.A.C.), when properly operated and maintained. Further, the system has passed the pressure* and bacteriological tests that were conducted in accordance with AWWA Standards.

This certification is based upon on-site observation of construction, scheduled and conducted by me or by a project representative under my direct supervision.

The use of the word "certify" or "certification" constitutes an expression of professional opinion regarding those facts or findings which are the subject of the certification, and does not constitute a warranty or guarantee, either expressed or implied.

Seal

Signature	Date
<u>Millard J. Yoder, P.E.</u>	<u>Reg. # 33765</u>
Name and Address	
<u>Smally, Wellford & Nalven, A Division of Wilson, Miller, Barton & Peek, Inc.</u>	
<u>P.O. Box 4069</u>	<u>Telephone No. 813 / 371-3690</u>
<u>Sarasota, FL 34230</u>	

III. Acceptance by Utility*

The subject system has been accepted for operation and maintenance.

*In case of water distribution system or water main extension

Signature	Date
<u>Leonard A. Smally, P.E., Director of Public</u>	
Name and Title	Works
<u>Town of Longboat Key</u>	

Instructions

The following supporting material must be submitted with this form:

1. One (1) set of record drawings; in case of water distribution system or water main, the sample points must be indicated.

2. Results of the bacteriological tests -

Please note that satisfactory bacteriological results for clearance for all parts of a community or non-community water supply facility except wells shall be two (2) consecutive daily samples with results of less than one (1) coliform per 100 milliliters of sample. For a community or non-community water supply system well clearance, a minimum of twenty (20) consecutive samples are required with no more than two (2) samples taken daily. Well sample results shall not exceed four (4) coliform per 100 milliliters of sample in more than ten percent (10%) of the samples analyzed. Sample results from any community or non-community water supply facility shall not be accepted on any analysis with TNTC or heavy non-coliform counts.

3. In case of well construction, a "Well Completion Report" must be submitted by the well driller.

This request must be accompanied by certification of completion of the sewerage system (if applicable).



State of Florida
Department of Environmental Regulation

Request for Letter of Release to Place Water Supply System into Service

I. General Information

Name of Project: L'Ambiance

Permit No. WD 1098-90-002

Date of Issuance 10/26/90

System completed to the full extent of the approved plans

Partially completed to the extent noted herein

Potable water lines to serve the south building, and pool area; included is the connection to the Town of Longboat Key water main.

II. Engineer's Certification

This is to certify that the project has been substantially completed in accordance with approved plans and specifications, or that the deviations noted on the attached record drawings will not prevent the system from functioning in compliance with requirements of Chapter 17-555, Florida Administrative Code (F.A.C.), when properly operated and maintained. Further, the system has passed the pressure* and bacteriological tests that were conducted in accordance with AWWA Standards.

This certification is based upon on-site observation of construction, scheduled and conducted by me or by a project representative under my direct supervision.

The use of the word "certify" or "certification" constitutes an expression of professional opinion regarding those facts or findings which are the subject of the certification, and does not constitute a warranty or guarantee, either expressed or implied.

Seal

Signature	Date
<u>Millard J. Yoder, P.E.</u>	<u>Reg. # 33765</u>
<u>Name and Address</u>	
<u>Smally, Wellford & Naiven, A Division of Wilson, Miller, Barton & Peek, Inc.</u>	
<u>P.O. Box 4069</u>	<u>Telephone No. 813 / 371-3690</u>
<u>Sarasota, FL 34230</u>	

III. Acceptance by Utility*

The subject system has been accepted for operation and maintenance.

*In case of water distribution system or water main extension

Signature	Date
<u>Leonard A. Smally, P.E., Director of Public</u>	<u>Works</u>
<u>Name and Title</u>	
<u>Town of Longboat Key</u>	

Instructions

The following supporting material must be submitted with this form:

1. One (1) set of record drawings; in case of water distribution system or water main, the sample points must be indicated.

2. Results of the bacteriological tests -

Please note that satisfactory bacteriological results for clearance for all parts of a community or non-community water supply facility except wells shall be two (2) consecutive daily samples with results of less than one (1) coliform per 100 milliliters of sample. For a community or non-community water supply system well clearance, a minimum of twenty (20) consecutive samples are required with no more than two (2) samples taken daily. Well sample results shall not exceed four (4) coliform per 100 milliliters of sample in more than ten percent (10%) of the samples analyzed. Sample results from any community or non-community water supply facility shall not be accepted on any analysis with TNTC or heavy non-coliform counts.

3. In case of well construction, a "Well Completion Report" must be submitted by the well driller.

This request must be accompanied by certification of completion of the sewerage system (if applicable).



State of Florida
Department of Environmental Regulation

Request for Letter of Release to Place Water Supply System into Service

I. General Information

Name of Project: L'Ambiance

Permit No. WD 1098-90-002

Date of Issuance 10/26/90

System completed to the full extent of the approved plans

Partially completed to the extent noted herein

Potable water lines to serve the south building, and pool area; included is the connection to the Town of Longboat Key water main.

II. Engineer's Certification

This is to certify that the project has been substantially completed in accordance with approved plans and specifications, or that the deviations noted on the attached record drawings will not prevent the system from functioning in compliance with requirements of Chapter 17-555, Florida Administrative Code (F.A.C.), when properly operated and maintained. Further, the system has passed the pressure* and bacteriological tests that were conducted in accordance with AWWA Standards.

This certification is based upon on-site observation of construction, scheduled and conducted by me or by a project representative under my direct supervision.

The use of the word "certify" or "certification" constitutes an expression of professional opinion regarding those facts or findings which are the subject of the certification, and does not constitute a warranty or guarantee, either expressed or implied.

Seal

Signature	Date
<u>Millard J. Yoder, P.E.</u>	<u>Reg. # 33765</u>
<u>Name and Address</u>	
<u>Smally, Wellford & Naiven, A Division of Wilson, Miller, Barton & Peek, Inc.</u>	
<u>P.O. Box 4069</u>	<u>Telephone No. 813 / 371-3690</u>
<u>Sarasota, FL 34230</u>	

III. Acceptance by Utility*

The subject system has been accepted for operation and maintenance.

*In case of water distribution system or water main extension

Signature	Date
<u>Leonard A. Smally, P.E., Director of Public</u>	
<u>Name and Title</u>	<u>Works</u>
<u>Town of Longboat Key</u>	

Instructions

The following supporting material must be submitted with this form:

1. One (1) set of record drawings; in case of water distribution system or water main, the sample points must be indicated.

2. Results of the bacteriological tests -

Please note that satisfactory bacteriological results for clearance for all parts of a community or non-community water supply facility except wells shall be two (2) consecutive daily samples with results of less than one (1) coliform per 100 milliliters of sample. For a community or non-community water supply system well clearance, a minimum of twenty (20) consecutive samples are required with no more than two (2) samples taken daily. Well sample results shall not exceed four (4) coliform per 100 milliliters of sample in more than ten percent (10%) of the samples analyzed. Sample results from any community or non-community water supply facility shall not be accepted on any analysis with TNTC or heavy non-coliform counts.

3. In case of well construction, a "Well Completion Report" must be submitted by the well driller.

This request must be accompanied by certification of completion of the sewerage system (if applicable).



State of Florida
Department of Environmental Regulation

Request for Letter of Release to Place Water Supply System into Service

I. General Information

Name of Project: L'Ambiance

Permit No. WD 1098-90-002

Date of Issuance 10/26/90

System completed to the full extent of the approved plans

Partially completed to the extent noted herein

Potable water lines to serve the south building, and pool area; included is the connection to the Town of Longboat Key water main.

II. Engineer's Certification

This is to certify that the project has been substantially completed in accordance with approved plans and specifications, or that the deviations noted on the attached record drawings will not prevent the system from functioning in compliance with requirements of Chapter 17-555, Florida Administrative Code (F.A.C.), when properly operated and maintained. Further, the system has passed the pressure* and bacteriological tests that were conducted in accordance with AWWA Standards.

This certification is based upon on-site observation of construction, scheduled and conducted by me or by a project representative under my direct supervision.

The use of the word "certify" or "certification" constitutes an expression of professional opinion regarding those facts or findings which are the subject of the certification, and does not constitute a warranty or guarantee, either expressed or implied.

Seal

Signature	Date
<u>Millard J. Yoder, P.E.</u>	<u>Reg. # 33765</u>
Name and Address	
<u>Smally, Wellford & Nalven, A Division of Wilson, Miller, Barton & Peek, Inc.</u>	
<u>P.O. Box 4069</u>	<u>Telephone No. 813 / 371-3690</u>
<u>Sarasota, FL 34230</u>	

III. Acceptance by Utility*

The subject system has been accepted for operation and maintenance.

*In case of water distribution system or water main extension

Signature	Date
<u>Leonard A. Smally, P.E., Director of Public</u>	
Name and Title	Works
<u>Town of Longboat Key</u>	

Instructions

The following supporting material must be submitted with this form:

1. One (1) set of record drawings; in case of water distribution system or water main, the sample points must be indicated.

2. Results of the bacteriological tests -

Please note that satisfactory bacteriological results for clearance for all parts of a community or non-community water supply facility except wells shall be two (2) consecutive daily samples with results of less than one (1) coliform per 100 milliliters of sample. For a community or non-community water supply system well clearance, a minimum of twenty (20) consecutive samples are required with no more than two (2) samples taken daily. Well sample results shall not exceed four (4) coliform per 100 milliliters of sample in more than ten percent (10%) of the samples analyzed. Sample results from any community or non-community water supply facility shall not be accepted on any analysis with TNTC or heavy non-coliform counts.

3. In case of well construction, a "Well Completion Report" must be submitted by the well driller.

This request must be accompanied by certification of completion of the sewerage system (if applicable).



State of Florida
Department of Environmental Regulation

Request for Letter of Release to Place Water Supply System into Service

I. General Information

Name of Project: L'Ambiance

Permit No. WD 1098-90-002

Date of Issuance 10/26/90

System completed to the full extent of the approved plans

Partially completed to the extent noted herein

Potable water lines to serve the south building, and pool area; included is
the connection to the Town of Longboat Key water main.

II. Engineer's Certification

This is to certify that the project has been substantially completed in accordance with approved plans and specifications, or that the deviations noted on the attached record drawings will not prevent the system from functioning in compliance with requirements of Chapter 17-555, Florida Administrative Code (F.A.C.), when properly operated and maintained. Further, the system has passed the pressure* and bacteriological tests that were conducted in accordance with AWWA Standards.

This certification is based upon on-site observation of construction, scheduled and conducted by me or by a project representative under my direct supervision.

The use of the word "certify" or "certification" constitutes an expression of professional opinion regarding those facts or findings which are the subject of the certification, and does not constitute a warranty or guarantee, either expressed or implied.

Seal

Signature	Date
<u>Millard J. Yoder, P.E.</u>	<u>Reg. # 33765</u>
Name and Address	
<u>Smally, Wellford & Nalven, A Division of Wilson,</u>	
<u>Miller, Barton & Peek, Inc.</u>	
<u>P.O. Box 4069</u>	<u>Telephone No. 813 / 371-3690</u>
<u>Sarasota, FL 34230</u>	

III. Acceptance by Utility*

The subject system has been accepted for operation and maintenance.

*In case of water distribution system or water main extension

Signature	Date
<u>Leonard A. Smally, P.E., Director of Public</u>	
Name and Title	Works
<u>Town of Longboat Key</u>	

Instructions

The following supporting material must be submitted with this form:

1. One (1) set of record drawings; in case of water distribution system or water main, the sample points must be indicated.

2. Results of the bacteriological tests -

Please note that satisfactory bacteriological results for clearance for all parts of a community or non-community water supply facility except wells shall be two (2) consecutive daily samples with results of less than one (1) coliform per 100 milliliters of sample. For a community or non-community water supply system well clearance, a minimum of twenty (20) consecutive samples are required with no more than two (2) samples taken daily. Well sample results shall not exceed four (4) coliform per 100 milliliters of sample in more than ten percent (10%) of the samples analyzed. Sample results from any community or non-community water supply facility shall not be accepted on any analysis with TNTC or heavy non-coliform counts.

3. In case of well construction, a "Well Completion Report" must be submitted by the well driller.

This request must be accompanied by certification of completion of the sewerage system (if applicable).